

Inspection of School

Status Code: A

Water Supply: Municipal/Community On-Site Supply

Water sample taken today? Inspection

Re-inspection

Name Change

Wastewater: Municipal/Community On-Site System

Yes No

Visit

Verification of Closure

Status Change

Name of School: SCOTTS RIDGE ELEMENTARY SCHOOL

Location Address: 6601 APEX BARBECUE RD

Mailing Addr: 1551 ROCK QUARRY ROAD

City: APEX

State: NC

Zip: 27502

City: RALEIGH

State: NC

Zip: 27610

	Score	Comments
1. WATER SUPPLY: Approved water supply properly located, constructed, and operated, adequate for all requirements 130*; well house clean, no storage 15*; no cross connections 30* (.2405)	175	** SEE COMMENT SHEET ATTACHED **
2. SANITARY SEWAGE DISPOSAL: Sewage collected, treated, and disposed of by an approved method 150*; system properly operated and maintained 55* (.2407)	205	
3. DRINKING FOUNTAINS: Clean and in good repair 40#; adequate pressure, properly regulated 40# (.2406)	80	
4. TOILET FACILITIES: Walls and ceilings clean, nonabsorbent, washable, and in good repair 30#; fixtures clean and in good repair 40#; floors impervious, kept clean 30# (.2408)	100	20
5. LAVATORY FACILITIES: Fixtures clean and in good repair 30#; soap and individual towels or approved hand-drying devices provided 40# (.2409)	70	15
6. FLOORS: WALLS: AND CEILINGS: Floors, walls, and ceilings clean and in good repair 30# (.2410)	30	15
7. STORAGE SPACES: Clean 20#; storage off floor 20# (.2411)	40	
8. LIGHTING AND VENTILATION: Fixtures, grills, vents, blinds, drapes, etc., clean and in good repair 40# (.2412)	40	20
9. DRESSING ROOMS AND SHOWERS: Floors, walls, and ceilings clean, in good repair, washable, non-absorbent 30#; fixtures clean, in good repair 40#; facilities for storage of clothes provided, kept clean 20#; soap and towel 10* (.2413)	100	
10. SOLID WASTE DISPOSAL: Impervious, cleanable containers with lids, approved type 20*; clean and in good repair 20#; empties as needed, properly disposed of 40# (.2414)	80	
11. PREMISES: MISCELLANEOUS: Premises neat, clean 30#; no vector breeding or harborage 20#; pesticides and other toxic materials properly handled and stored 30* (.2415)	80	15
TOTAL	1000	85

Additional Comment Sheet Attached

Yes No

Inspection by:

J.D. REHS

EHS 1746 - Dunn, Jason

INSTRUCTIONS Purpose: General Statute 130A-236 requires the Commission for Health Services to adopt rules governing the sanitation of public, private, and religious schools. This form has been developed to record the results of such inspections. Preparation: Local environmental health specialists shall complete the form every time they conduct an inspection. Prepare an original and two copies for: 1. Original to be left with principal. 2. Copy for the local health department. 3. Copy for the Environmental Health Services Section, Division of Environmental Health. Disposition: Please refer to Records Retention and Disposition Schedule 8.B.6., Inspection Records for County/District Health Departments which is published by the North Carolina Division of Archives & History. Additional forms may be ordered from: Division of Environmental Health, 1632 Mail Service Center, Raleigh, NC 27699-1632, (Courier 52-01-00) EHS 1163 (Revised 7/05) Environmental Health Services Section (Review 7/08)

Comment Addendum to Inspection Report

Establishment Name: SCOTTS RIDGE ELEMENTARY SCHOOL

Establishment ID: 4092440425

Date: 09/30/2025 **Time In:** 10:00 AM **Time Out:** 1:00 PM

Observations and Corrective Actions

4	The toilet in staff bathroom #101F is partially clogged and is backing up frequently per notice of the school custodian. Any blockages in the drain pipe for this toilet should be removed to allow this toilet to flush and drain properly.
5	Repair loose water flow control valve on the faucet of the classroom countertop hand wash sink in room #206
6	Replace broken window panes in the breezeway of the #100 hallway at music classroom #129 and on the ground level exterior exit door in stairway #300K. Priority repairs for safety are required due to the broken glass in these window panes. Repair door for the special needs class bathroom #121A. This door becomes stuck in the door frame and does not open easily when closed. Priority repairs for safety are required. Replace two missing drop ceiling panels in staff bathroom #300I. Clean grime, residue, buildup, and cobwebs from the exterior frame of the top floor window in stairway #2300G. Weeds are growing out of the gutters on the school building roof on the front exterior of the school building at the #200 hall above the entry door for stock room #219 and on the right side of the front porch awning at the main entrance. The roof gutters should be cleared of this buildup and weed growth to prevent interior ceiling leaks and to prevent rain water from overflowing the gutters and pooling up around the building foundation which can cause interior flooding.
8	Repair the nonfunctional air conditioning system in classroom #214 to allow for adequate ventilation. Repair two nonfunctional ceiling light fixtures in boys bathroom #2300E and two nonfunctional ceiling light fixtures on the #300 hallway by room #311.
11	The playhouse structure on the pre-k playground is covered in grime, build up, and residue and requires pressure wash cleaning.

Additional Comments

GC: School facility sanitation inspection completed.