

Inspection of School

Status Code: A

Water Supply: Municipal/Community On-Site Supply

Water sample taken today? Inspection

Re-inspection

Name Change

Wastewater: Municipal/Community On-Site System

Yes No

Visit

Verification of Closure

Status Change

Name of School: APOGEE TRIANGLE

Location Address: 3501 US 64 HIGHWAY, SUITE 102

Mailing Addr: PO BOX #3, 501 WEST WILLIAMS STREET

City: APEX

State: NC

Zip: 27523

City: APEX

State: NC

Zip: 27502

	Score	Comments
1. WATER SUPPLY: Approved water supply properly located, constructed, and operated, adequate for all requirements 130*; well house clean, no storage 15*; no cross connections 30* (.2405)	175	** SEE COMMENT SHEET ATTACHED **
2. SANITARY SEWAGE DISPOSAL: Sewage collected, treated, and disposed of by an approved method 150*; system properly operated and maintained 55* (.2407)	205	
3. DRINKING FOUNTAINS: Clean and in good repair 40#; adequate pressure, properly regulated 40# (.2406)	80	
4. TOILET FACILITIES: Walls and ceilings clean, nonabsorbent, washable, and in good repair 30#; fixtures clean and in good repair 40#; floors impervious, kept clean 30# (.2408)	100	
5. LAVATORY FACILITIES: Fixtures clean and in good repair 30#; soap and individual towels or approved hand-drying devices provided 40# (.2409)	70	
6. FLOORS: WALLS: AND CEILINGS: Floors, walls, and ceilings clean and in good repair 30# (.2410)	30	15
7. STORAGE SPACES: Clean 20#; storage off floor 20# (.2411)	40	
8. LIGHTING AND VENTILATION: Fixtures, grills, vents, blinds, drapes, etc., clean and in good repair 40# (.2412)	40	
9. DRESSING ROOMS AND SHOWERS: Floors, walls, and ceilings clean, in good repair, washable, non-absorbent 30#; fixtures clean, in good repair 40#; facilities for storage of clothes provided, kept clean 20#; soap and towel 10* (.2413)	100	
10. SOLID WASTE DISPOSAL: Impervious, cleanable containers with lids, approved type 20*; clean and in good repair 20#; empties as needed, properly disposed of 40# (.2414)	80	
11. PREMISES: MISCELLANEOUS: Premises neat, clean 30#; no vector breeding or harborage 20#; pesticides and other toxic materials properly handled and stored 30* (.2415)	80	
TOTAL	1000	15

Additional Comment Sheet Attached

Yes No

Inspection by:

J D - REHS

EHS 1746 - Dunn, Jason

INSTRUCTIONS Purpose: General Statute 130A-236 requires the Commission for Health Services to adopt rules governing the sanitation of public, private, and religious schools. This form has been developed to record the results of such inspections. Preparation: Local environmental health specialists shall complete the form every time they conduct an inspection. Prepare an original and two copies for: 1. Original to be left with principal. 2. Copy for the local health department. 3. Copy for the Environmental Health Services Section, Division of Environmental Health. Disposition: Please refer to Records Retention and Disposition Schedule 8.B.6., Inspection Records for County/District Health Departments which is published by the North Carolina Division of Archives & History. Additional forms may be ordered from: Division of Environmental Health, 1632 Mail Service Center, Raleigh, NC 27699-1632, (Courier 52-01-00) EHS 1163 (Revised 7/05) Environmental Health Services Section (Review 7/08)

Comment Addendum to Inspection Report

Establishment Name: APOGEE TRIANGLE

Establishment ID: 4092440579

Date: 07/03/2025 **Time In:** 2:00 PM **Time Out:** 4:00 PM

Observations and Corrective Actions

6	Upper walls of the gym should be made of a solid covering that is cleanable. Current upper gym walls have no covering and have exposed insulation present. Repair and retrofit of the upper gym walls to have a proper covering is required.
---	--

Additional Comments

GC: New school facility sanitation inspection completed. Approval of well and septic system for this facility were completed by Wake County Environmental Health On Site Wastewater Division and Wells Program prior to this sanitation inspection. Well water bacteriologic sampling was completed and verified as in compliance by Hiram Casebolt, REHS, with the Wake County Environmental Health Wells Program prior to the initial sanitation inspection of the school building.