

Sanitation Standards Evaluation Form for Child Care Centers

Demerits: 2

Classification: Superior Approved Provisional Disapproved CREATIVE LEARNING ENTERPRISES,

Establishment Name: FAIRVIEW CHILDREN'S CENTER

Operator: INC.

Location Address: 4309 TEN TEN RD

Date: 03/19/2026

Status Code: A

City: APEX State: North Carolina

Time In: 1:50 PM

Time Out: 3:15 PM

Zip: 27502 County: 92 Wake

Current Facility ID#: 4092420750 Telephone: (919) 362-0052

Licensing ID#: 92003237 Maximum Capacity: 119

Inspection Re-Inspection Visit
 Name Change Verification of Closure Status Change

Wastewater System:

Municipal/Community Onsite System

Water Supply:

Municipal/Community Onsite Supply

Water Sample Taken Today?

Yes No

Demerits	
HANDWASHING: .2803, .2836	
1. Handwashing when required	5
2. Proper handwashing procedure	5
FOOD: .2804, .2806, .2807, .2808, .2810, .2818, .2836	
*3. From approved sources, not a hazard or adulterated	6
*4. Potentially hazardous foods meet storage and holding temperatures; bottles, lunches refrigerated at 45° F or below	6
5. Food properly stored, thawed, prepared, cooked, cooled, handled, served, transported, packaged and identified; only supervised children in kitchen; water from a handwash lavatory not consumed or used for bottle warming	5
6. Not re-served	3
7. Thermometers provided, accurate	2 2
FOOD SERVICE EQUIPMENT & UTENSILS AND SANITIZING: .2806, .2809, .2810, .2812, .2814	
*8. Meets specifications for refrigeration, sinks, lavatories and dishwashing equipment	6
9. Meets specifications for other equipment and utensils, approved material and construction	4
10. Food contact surfaces properly washed, rinsed, sanitized and air dried; single-service articles not re-used	5
11. Approved sanitizing solution provided; test kit available	2
12. Equipment, non-food contact surfaces clean; in good repair	4
13. Proper storage and handling of clean equipment, utensils and single-service articles	3
WATER SUPPLY & DRINKING WATER FACILITIES: .2815, .2836	
*14. Water supply meets 15A NCAC 18A .1700 and 15A NCAC 18C if applicable; documentation provided	6
*15. Hot water supplied and maintained in the kitchen	6
16. Hot water supplied and tempered water maintained as required in all other areas	4
*17. Hot water in excess of 120°F not allowed in areas accessible to children	6
18. Backflow prevention provided, no cross connections	3
19. Approved drinking fountains, pressure regulated, clean	2
LEAD POISONING HAZARDS: .2816	
*20. No identified lead poisoning hazards in accordance with NCGS 130A-131.7(7); date water tested: 06/27/2024	6
TOILET AND LAVATORY FACILITIES: .2817, .2818, .2836	
21. Properly sized, located, accessible, and in good repair; sinks, toilets and potty chairs cleaned and disinfected; proper change of use procedure	4
22. Soap, approved hand drying devices, toilet tissue paper available	3
23. Approved storage in toilet rooms, lavatories free of storage; hand wash signs posted	2
DIAPER CHANGING FACILITIES AND DISINFECTION: .2812, .2817, .2818, .2819; .2820, .2836	
*24. Approved facilities as needed	6
*25. Diapering surfaces cleaned and disinfected after each use	6
26. Approved cleaning solution and approved disinfectant provided; test kit available when required	2
27. Free of storage and in good repair; cleaning and disinfecting solutions labeled; approved diapering methods used; approved floor barrier; diaper changing and handwash signs posted	4

Demerits	
STORAGE: .2820	
*28. Medications properly stored	6
*29. Hazardous products properly stored and locked	6
30. Non-hazardous products properly stored	3
31. Facilities provided for proper storage; used and kept clean	2
BEDS, COTS, MATS AND LINENS: .2821, .2836	
32. Adequate linen provided and properly stored; adequate beds, cots, mats provided, in good repair, properly stored, labeled, spaced during use	3
33. Linen, bedding, wash cloths, bibs, burping cloths laundered, and in good repair	3
TOYS, EQUIPMENT, FURNITURE: .2822, .2836	
34. Clean and in good repair; cleaning, sanitization and maintenance of water play centers	4
35. Mouth-contact surfaces cleaned and sanitized in rooms designated for children who are not toilet trained	4
PERSONNEL: .2807, .2823	
36. Child care center employees wearing gloves, clean clothes, hair restraints where required; no tobacco use	2
FLOORS, WALLS & CEILINGS: .2824, .2825, .2832, .2836	
37. Easily cleanable, clean, and in good repair; carpets vacuumed as required and extraction cleaned; date cleaned: _____	4
LIGHTING AND THERMAL ENVIRONMENT: .2826	
38. Room temperature between 65° F and 85° F	3
39. Equipment clean and in good repair; maintained as required	2
COMMUNICABLE DISEASE CONTROL: .2827, .2836	
*40. Persons with a communicable disease or condition excluded in accordance with 10A NCAC 41A .0200	6
41. Persons caring for sick or mildly ill children excluded from situations in which disease transmission likely to occur; proper written cleanup procedure followed for vomiting or diarrheal events	4
42. Designated area for sick children; maintained as required; written procedures for vomiting or diarrheal events	2
WASTEWATER: .2829	
*43. Approved sewage disposal	6
SOLID WASTE: .2830, .2836	
44. Solid waste properly handled; containers and cleaning equipment kept clean; can cleaning facilities adequate	2
ANIMAL & VERMIN CONTROL, OUTDOOR LEARNING ENVIRONMENT & PREMISES: .2831, .2832	
*45. Pesticides properly used; no new installation of CCA pressure-treated wood	6
46. CCA pressure-treated wood sealed; date sealed: _____; soil covered or inaccessible	2
47. No animals in food preparation areas and no unrestrained animals except as allowed; no prohibited animals; required veterinary records available and current	3
48. Pest control; premises free of conditions that harbor or attract pests	3
49. Premises clean and free of standing water; utility equipment inaccessible; equipment and toys clean and in good repair; sandboxes properly constructed, clean and covered; adherence to air quality forecast quality forecast outdoor activity restrictions when applicable	2
SWIMMING & WADING POOLS: .2833	
*50. Designed, constructed, operated and maintained in accordance with 15A NCAC 18A .2500	6

*Indicates critical item (6 demerits)

Signed: 

REHS#: 2583

Received By: 

Classification: Superior – 0-15 demerits, no 6-point demerit; Approved – 16-30 demerits, no 6-point demerit; Provisional – 31-45 demerits, or any 6-point demerit; Disapproved – 46 or more demerits, or failure to improve Provisional classification. An original and two copies of this form shall be completed by local Environmental Health Specialists during each inspection. The original is sent to the Division of Child Development and Early Education N.C. Department of Health and Human Services, one copy is given to the child care operator; and the other copy is kept by the local health department.



Comment Addendum to Inspection Report

Establishment Name: FAIRVIEW CHILDREN'S CENTER

Establishment ID: 4092420750

Date: 03/19/2026 **Time In:** 1:50 PM **Time Out:** 3:15 PM

Temperature Observations

Item	Location	Temp	Item	Location	Temp	Item	Location	Temp
Water	Child access	102	Water	Child access	103	Water	Child access	80
Water	Child access	106	Water	3 comp sink	120	Ambient air	Infant fridge	41
Cheese	Reach-in fridge in kitchen	41	Sanitizer	Throughout	200ppm	Disinfectant	Throughout	800ppm

Observations and Corrective Actions

7	15A NCAC 18A .2807 (h); The probe food thermometer in the kitchen was not able to turn on. A working food thermometer shall be held in the kitchen to ensure proper cooking and holding temperatures. Please obtain a working, thin probe food thermometer.
---	---

Additional Comments

GC: Note: High chair feeding trays shall be washed, rinsed and sanitized in the child care center kitchen after each use (15A NCAC 18A .2812(e)).

Specialty bulk milk that is sent from home for consumption by a child while at the child care center may be sent to the child care center at the beginning of each week unopened, labeled with the date received by the child care center, and labeled with the name of the child to whom the bulk specialty milk belongs. Any remaining bulk specialty milk shall be sent home at the end of the week with the child to whom the bulk specialty milk belongs.

If you have any questions/concerns, please feel free to call 919-868-6416 or email meghan.scott@wake.gov