

Demerit Score: 6

Date of Insp/Chg: 04/29/2025
Status Code: A

Health Department 92

Current Facility ID 4092500619

Old Facility ID

Inspection of Swimming Pool

Water Supply: Municipal/Community On-Site Supply
Wastewater: Municipal/Community On-Site System

Water sample taken today?

Yes No

Inspection

Re-inspection

Visit

Name Change

Verification of Closure

Status Change

Name of Establishment: GREENBRIER S/D POOL

Pool Operator: Nick Tipling
(F, L)

Location Address: 608 BRICKSTONE DR

Mailing Addr. P.O. BOX 9106

City: APEX State: NC Zip: 27502

City: CHAPEL HILL State: NC Zip: 27615

* Indicates critical item (6-point demerit)

WATER QUALITY: (.2535)

- *1. Water clear enough to clearly see bottom of pool and pool drain 6
- *2. Disinfectant residual provided by:
 - free chlorine = 3.0 (at least 1.0 ppm or 2.0 ppm where required); 6
 - bromine = (at least 2.0 ppm); or 6
 - biguanide = (30 to 50 ppm)..... 6
- *3. Pool water pH = 7.3 (7.2 to 7.8)..... 6
- *4. Water temperature of heated pool °F; does not exceed 90°F
(swimming pool) or 104°F (spa) 6
- 5. Daily written records of water quality and test kit kept on site 4

Comments:

** SEE COMMENT SHEET ATTACHED **

POOL MAINTENANCE:

- *6. Submerged suction outlets meet ASME/ANSI A112.19.8-2007. Single drains protected.(.2537, .2539) GPM=0 Field verification complete=Yes 6
- 7. Pool walls and floor kept clean, free of debris and in good repair (.2537)... 4
- 8. Surface skimmers (with weirs, baskets and covers) or gutters clean, in good repair, and functioning properly, no floating debris (.2518, .2537) 4
- 9. Depth markings and no diving markers or signs visible and properly located (.2523, .2537)..... 4
- 10. Safety ropes with floats and contrasting color bands provided at shallow area breakpoints (.2515, .2523)..... 2
- 11. Diving equipment, ladders, steps and handrails properly placed, in good repair (.2517, .2521)..... 2
- 12. Inlets and other fittings in place and in good repair (.2537)..... 4
- 13. Contrasting band on steps and benches (.2521, .2516, .2532)..... 4
- 14. Spa timer working properly (.2537)..... 4

PREMISES:

- *15. Body hook and ring buoy with throw rope or lifeguard with rescue tube provided and properly located (.2530, .2537) 6
- 16. Fence or barrier with self-closing, self-latching gates properly constructed and maintained (.2528, .2537) 4
- 17. Decks unobstructed, properly drained, free of trip hazards (.2522, .2537)..... 4
- 18. Lifeguards present or warning signs posted (.2530) 4
- 19. Signs prohibit glass containers or pets in pool area(.2530) 4
- 20. Caution signs posted at hot water spas (.2532) 4
- 21. Pool and deck lighting provided at pools that operate at night (.2524, .2537) ... 4
- *22. Emergency telephone provided (.2530) 6

EQUIPMENT ROOM:

- 23. Chlorine or bromine automatic feeders that meet NSF Standard 50 (.2535) 4
- 24. Approved pump, filter, and flow meter operating properly (2518, .2519) 4
- 25. Equipment and chemicals kept in a dry, well-ventilated enclosure (.2533, .2534, .2537) 2
- 26. Valves and pipes identified by color codes or labels (.2518) 2
- 27. Filter backwash discharged through an air gap (.2513) 2

DRESSING AND SANITARY FACILITIES:

- 28. Bathroom or rest rooms accessible; shower sign posted (.2526) 2
- 29. Required fixtures provided, clean, and in good repair (.2526) 2
- 30. Approved water source, no cross connections (.2512) 2
- 31. Sewage disposed of in a properly operating sewage system (.2513) 2
- 32. Floors smooth, slip-resistant, kept clean(.2526) 2
- 33. Hose bibbs and floor drains provided (.2526) 2

Comment Sheet Attached

Yes No

Report Received by:

Ben Dunn

Inspection

Conducted by: *J D KEHS*

EHS I.D. # 1746 - Dunn, Jason

Comment Addendum to Inspection Report

Establishment Name: GREENBRIER S/D POOL

Establishment ID: 4092500619

Date: 04/29/2025 **Time In:** 3:00 PM **Time Out:** 4:15 PM

Observations and Corrective Actions

11 Repair bent and uneven top step on pool ladder in five foot pool depth adjacent to the bath house.

24 Flow meter is not accurate and requires replacement.

Additional Comments

Skimmer equalizer wall drain covers have been properly abandoned and sealed. Documentation of abandonment procedures have been forwarded to Wake County Environmental Health Plan Review Division and work was approved.

Seasonal pool operation permit issued on 04/29/25.

Pool operation permit expires on 10/31/2025.

Visible bonding wiring was intact and securely attached to the pool pump at the time of inspection.

Pool is permitted for daylight use only. No night swimming allowed.

Pool equipment on site matches VGB approval data on file.