

Inspection of Swimming Pool

Water Supply: Municipal/Community On-Site Supply
Wastewater: Municipal/Community On-Site System

Water sample taken today?
 Yes No

Inspection Name Change
 Re-inspection Verification of Closure
 Visit Status Change

Name of Establishment: SWEETWATER POOL

Pool Operator: Jake Clifford
(F, L)

Location Address: 2775 CORE BANKS ST

Mailing Addr. 812 SALEM WOODS DR, 101

City: APEX State: NC Zip: 27523

City: RALEIGH State: NC Zip: 27614

WATER QUALITY: (.2535)

* Indicates critical item (6-point demerit)

- *1. Water clear enough to clearly see bottom of pool and pool drain 6
- *2. Disinfectant residual provided by:
 - free chlorine = 5.0 (at least 1.0 ppm or 2.0 ppm where required);
 - bromine = (at least 2.0 ppm); or
 - biguanide = (30 to 50 ppm)..... 6
- *3. Pool water pH = 7.4 (7.2 to 7.8)..... 6
- *4. Water temperature of heated pool °F; does not exceed 90°F
(swimming pool) or 104°F (spa) 6
- 5. Daily written records of water quality and test kit kept on site 4

Comments:

**** SEE COMMENT SHEET ATTACHED ****

POOL MAINTENANCE:

- *6. Submerged suction outlets meet ASME/ANSI A112.19.8-2007. Single drains protected.(.2537, .2539) GPM=370 Field verification complete=Yes 6
- 7. Pool walls and floor kept clean, free of debris and in good repair (.2537)... 4
- 8. Surface skimmers (with weirs, baskets and covers) or gutters clean, in good repair, and functioning properly, no floating debris (.2518, .2537) 4
- 9. Depth markings and no diving markers or signs visible and properly located (.2523, .2537)..... 4
- 10. Safety ropes with floats and contrasting color bands provided at shallow area breakpoints (.2515, .2523)..... 2
- 11. Diving equipment, ladders, steps and handrails properly placed, in good repair (.2517, .2521)..... 2
- 12. Inlets and other fittings in place and in good repair (.2537)..... 4
- 13. Contrasting band on steps and benches (.2521, .2516, .2532)..... 4
- 14. Spa timer working properly (.2537)..... 4

PREMISES:

- *15. Body hook and ring buoy with throw rope or lifeguard with rescue tube provided and properly located (.2530, .2537) 6
- 16. Fence or barrier with self-closing, self-latching gates properly constructed and maintained (.2528, .2537) 4
- 17. Decks unobstructed, properly drained, free of trip hazards (.2522, .2537)..... 4
- 18. Lifeguards present or warning signs posted (.2530) 4
- 19. Signs prohibit glass containers or pets in pool area(.2530) 4
- 20. Caution signs posted at hot water spas (.2532) 4
- 21. Pool and deck lighting provided at pools that operate at night (.2524, .2537) ... 4
- *22. Emergency telephone provided (.2530) 6

EQUIPMENT ROOM:

- 23. Chlorine or bromine automatic feeders that meet NSF Standard 50 (.2535) 4
- 24. Approved pump, filter, and flow meter operating properly (2518, .2519) 4
- 25. Equipment and chemicals kept in a dry, well-ventilated enclosure (.2533, .2534, .2537) 2
- 26. Valves and pipes identified by color codes or labels (.2518) 2
- 27. Filter backwash discharged through an air gap (.2513) 2

DRESSING AND SANITARY FACILITIES:

- 28. Bathroom or rest rooms accessible; shower sign posted (.2526) 2
- 29. Required fixtures provided, clean, and in good repair (.2526) 2
- 30. Approved water source, no cross connections (.2512) 2
- 31. Sewage disposed of in a properly operating sewage system (.2513) 2
- 32. Floors smooth, slip-resistant, kept clean(.2526) 2
- 33. Hose bibbs and floor drains provided (.2526) 2

Comment Sheet Attached

Yes No

Report Received by:

Jason Dunn *Jay*

Inspection

Conducted by: *J D - KEHS*

EHS I.D. # 1746 - Dunn, Jason

Comment Addendum to Inspection Report

Establishment Name: SWEETWATER POOL

Establishment ID: 4092501141

Date: 05/07/2025 **Time In:** 10:30 AM **Time Out:** 1:00 PM

Observations and Corrective Actions

- 8 Repair loose and damaged interior liners in the throat of four of the pool skimmers. Repairs are needed to allow for ease of cleaning out the skimmer interior baskets. Replace missing weir in one pool skimmer.
- 32 Repair and seal crack that runs along the pool floor from the sun shelf to the interior pool steps.

Additional Comments

Seasonal pool permit issued on 05/07/2025.

Pool operation permit expires on 10/31/2025.

Pool is permitted for daylight use only. No night time swimming allowed.

Visible bonding wiring was intact and securely attached to the pool pumps at the time of pool inspection.

VGB data on file matches pool equipment present on site at the time of pool inspection.

Pool is not using liquid chlorine for disinfection this season and has switched to a saline system.