

Demerit Score: 0

Date of Insp/Chg: 05/01/2025  
Status Code: A

Health Department 92  
Current Facility ID 4092501177  
Old Facility ID

Inspection of Swimming Pool

Water Supply:  Municipal/Community  On-Site Supply  
Wastewater:  Municipal/Community  On-Site System

Water sample taken today?  Yes  No  
 Inspection  Name Change  
 Re-inspection  Verification of Closure  
 Visit  Status Change

Name of Establishment: SMITH FARM AMENITY POOL

Pool Operator: (F, L)

Location Address: 2950 FARMHOUSE DR

Mailing Addr. 4112 BLUE RIDGE RD

City: APEX State: NC Zip: 27502

City: RALEIGH State: NC Zip: 27612

WATER QUALITY: (.2535)

\* Indicates critical item (6-point demerit)

- \*1. Water clear enough to clearly see bottom of pool and pool drain ..... 0 6
- \*2. Disinfectant residual provided by:  
free chlorine = 2.0 (at least 1.0 ppm or 2.0 ppm where required); 0 6  
bromine = (at least 2.0 ppm); or  
biguanide = (30 to 50 ppm)..... 0 6
- \*3. Pool water pH = 7.4 (7.2 to 7.8)..... 0 6
- \*4. Water temperature of heated pool °F; does not exceed 90°F (swimming pool) or 104°F (spa) ..... 0 6
- 5. Daily written records of water quality and test kit kept on site ..... 0 4

Comments:  
\*\* SEE COMMENT SHEET ATTACHED \*\*

POOL MAINTENANCE:

- \*6. Submerged suction outlets meet ASME/ANSI A112.19.8-2007. Single drains protected.(.2537, .2539) GPM=260 Field verification complete=Yes 0 6
- 7. Pool walls and floor kept clean, free of debris and in good repair (.2537)... 0 4
- 8. Surface skimmers (with weirs, baskets and covers) or gutters clean, in good repair, and functioning properly, no floating debris (.2518, .2537) ..... 0 4
- 9. Depth markings and no diving markers or signs visible and properly located (.2523, .2537)..... 0 4
- 10. Safety ropes with floats and contrasting color bands provided at shallow area breakpoints (.2515, .2523)..... 0 2
- 11. Diving equipment, ladders, steps and handrails properly placed, in good repair (.2517, .2521)..... 0 2
- 12. Inlets and other fittings in place and in good repair (.2537)..... 0 4
- 13. Contrasting band on steps and benches (.2521, .2516, .2532)..... 0 4
- 14. Spa timer working properly (.2537)..... 0 4

PREMISES:

- \*15. Body hook and ring buoy with throw rope or lifeguard with rescue tube provided and properly located (.2530, .2537) ..... 0 6
- 16. Fence or barrier with self-closing, self-latching gates properly constructed and maintained (.2528, .2537) ..... 0 4
- 17. Decks unobstructed, properly drained, free of trip hazards (.2522, .2537)..... 0 4
- 18. Lifeguards present or warning signs posted (.2530) ..... 0 4
- 19. Signs prohibit glass containers or pets in pool area(.2530) ..... 0 4
- 20. Caution signs posted at hot water spas (.2532) ..... 0 4
- 21. Pool and deck lighting provided at pools that operate at night (.2524, .2537) ... 0 4
- \*22. Emergency telephone provided (.2530) ..... 0 6

EQUIPMENT ROOM:

- 23. Chlorine or bromine automatic feeders that meet NSF Standard 50 (.2535) ..... 0 4
- 24. Approved pump, filter, and flow meter operating properly (2518, .2519) ..... 0 4
- 25. Equipment and chemicals kept in a dry, well-ventilated enclosure (.2533, .2534, .2537) ..... 0 2
- 26. Valves and pipes identified by color codes or labels (.2518) ..... 0 2
- 27. Filter backwash discharged through an air gap (.2513) ..... 0 2

DRESSING AND SANITARY FACILITIES:

- 28. Bathroom or rest rooms accessible; shower sign posted (.2526) ..... 0 2
- 29. Required fixtures provided, clean, and in good repair (.2526) ..... 0 2
- 30. Approved water source, no cross connections (.2512) ..... 0 2
- 31. Sewage disposed of in a properly operating sewage system (.2513) ..... 0 2
- 32. Floors smooth, slip-resistant, kept clean(.2526) ..... 0 2
- 33. Hose bibbs and floor drains provided (.2526) ..... 0 2

Comment Sheet Attached

Yes  No

Report Received by:

*[Signature]*

Inspection Conducted by:

*J.D. REHS*

EHS I.D. # 1746 - Dunn, Jason

## Comment Addendum to Inspection Report

**Establishment Name:** SMITH FARM AMENITY POOL

**Establishment ID:** 4092501177

**Date:** 05/01/2025 **Time In:** 1:00 PM **Time Out:** 3:30 PM

### Additional Comments

No demerits at the time of inspection.

Seasonal pool operation permit issued on 05/01/2025.

Pool operation permit expires on 10/31/2025.

Pool is approved for daylight use only. No night swimming allowed.

Flow meter was functional at the time of inspection.

VGB approval data on file matches equipment present on site.

Automatic shutoff for liquid chlorine feeder was functional at the time of inspection.

Visible bonding wiring was intact and securely attached to the pool pumps at the time of inspection.