

Score 96.5

Health Department 92 Wake

Date of Insp/Chg: 07/24/2026

Current Facility ID 4092440329

Inspection of School

Status Code: A

Old Facility ID _____

Water Supply: ☒ Municipal/Community ☐ On-Site Supply

Water sample taken today? ☒ Inspection ☐ Name Change

☐ Yes ☒ No

☐ Re-inspection

☐ Verification of Closure

Wastewater: ☒ Municipal/Community ☐ On-Site System

☐ Visit

☐ Status Change

Name of School: THALES ACADEMY IN APEX

Location Address: 1177 AMBERGATE STATION

Mailing Addr: 1177 AMBERGATE STATION

City: APEX State: NC Zip: 27502

City: APEX State: NC Zip: 27502

	Score	Comments
1. WATER SUPPLY: Approved water supply properly located, constructed, and operated, adequate for all requirements 130*; well house clean, no storage 15*; no cross connections 30* (.2405)	175	** SEE COMMENT SHEET ATTACHED **
2. SANITARY SEWAGE DISPOSAL: Sewage collected, treated, and disposed of by an approved method 150*; system properly operated and maintained 55* (.2407)	205	
3. DRINKING FOUNTAINS: Clean and in good repair 40#; adequate pressure, properly regulated 40# (.2406)	80	
4. TOILET FACILITIES: Walls and ceilings clean, nonabsorbent, washable, and in good repair 30#; fixtures clean and in good repair 40#; floors impervious, kept clean 30# (.2408)	100	20
5. LAVATORY FACILITIES: Fixtures clean and in good repair 30#; soap and individual towels or approved hand-drying devices provided 40# (.2409)	70	
6. FLOORS: WALLS: AND CEILINGS: Floors, walls, and ceilings clean and in good repair 30# (.2410)	30	
7. STORAGE SPACES: Clean 20#; storage off floor 20# (.2411)	40	
8. LIGHTING AND VENTILATION: Fixtures, grills, vents, blinds, drapes, etc., clean and in good repair 40# (.2412)	40	
9. DRESSING ROOMS AND SHOWERS: Floors, walls, and ceilings clean, in good repair, washable, non-absorbent 30#; fixtures clean, in good repair 40#; facilities for storage of clothes provided, kept clean 20#; soap and towel 10* (.2413)	100	
10. SOLID WASTE DISPOSAL: Impervious, cleanable containers with lids, approved type 20*; clean and in good repair 20#; empties as needed, properly disposed of 40# (.2414)	80	
11. PREMISES: MISCELLANEOUS: Premises neat, clean 30#; no vector breeding or harborage 20#; pesticides and other toxic materials properly handled and stored 30* (.2415)	80	15
TOTAL	1000	35

Additional Comment Sheet Attached

☒ Yes ☐ No

Inspection by: J.D. REHS

EHS 1746 - Dunn, Jason

INSTRUCTIONS Purpose: General Statute 130A-236 requires the Commission for Health Services to adopt rules governing the sanitation of public, private, and religious schools. This form has been developed to record the results of such inspections. Preparation: Local environmental health specialists shall complete the form every time they conduct an inspection. Prepare an original and two copies for: 1. Original to be left with principal. 2. Copy for the local health department. 3. Copy for the Environmental Health Services Section, Division of Environmental Health. Disposition: Please refer to Records Retention and Disposition Schedule 8.B.6., Inspection Records for County/District Health Departments which is published by the North Carolina Division of Archives & History. Additional forms may be ordered from: Division of Environmental Health, 1632 Mail Service Center, Raleigh, NC 27699-1632, (Courier 52-01-00)
EHS 1163 (Revised 7/05) Environmental Health Services Section (Review 7/08)

Comment Addendum to Inspection Report

Establishment Name: THALES ACADEMY IN APEX

Establishment ID: 4092440329

Date: 07/24/2026 **Time In:** 12:30 PM **Time Out:** 2:30 PM

Observations and Corrective Actions

4	Repair leak on the plumbing pipework of one toilet in boys bathroom #135. This toilet leaks when flushed.
11	Repair loose handhold on the top entrance of the middle slide on the large playground structure.

Additional Comments

GC: Cables on the lock for the perimeter fence gate entrance into the retention pond enclosure should be coiled tightly so that the gate can not be easily opened by children for access. At the time of the inspection the gate lock cables were very loose and the gate could still be widely opened. Allowing children easy access to the interior pond area. Adjustments for safety are needed.

School facility sanitation inspection completed.