

Score 96.5

Health Department 92 Wake

Date of Insp/Chg: 07/20/2026

Current Facility ID 4092440460

Inspection of School

Status Code: A

Old Facility ID _____

Water Supply: ☒ Municipal/Community ☐ On-Site Supply

Water sample taken today? ☒ Inspection ☐ Name Change

☐ Yes ☒ No

☐ Re-inspection

☐ Verification of Closure

Wastewater: ☒ Municipal/Community ☐ On-Site System

☐ Visit

☐ Status Change

Name of School: THALES ACADEMY APEX JUNIOR HIGH SCHOOL

Location Address: 1300 N SALEM ST

Mailing Addr: 4641 PARAGON PARK DR.

City: APEX State: NC Zip: 27502 City: RALEIGH State: NC Zip: 27616

	Score	Comments
1. WATER SUPPLY: Approved water supply properly located, constructed, and operated, adequate for all requirements 130*; well house clean, no storage 15*; no cross connections 30* (.2405)	175	** SEE COMMENT SHEET ATTACHED **
2. SANITARY SEWAGE DISPOSAL: Sewage collected, treated, and disposed of by an approved method 150*; system properly operated and maintained 55* (.2407)	205	
3. DRINKING FOUNTAINS: Clean and in good repair 40#; adequate pressure, properly regulated 40# (.2406)	80	
4. TOILET FACILITIES: Walls and ceilings clean, nonabsorbent, washable, and in good repair 30#; fixtures clean and in good repair 40#; floors impervious, kept clean 30# (.2408)	100	20
5. LAVATORY FACILITIES: Fixtures clean and in good repair 30#; soap and individual towels or approved hand-drying devices provided 40# (.2409)	70	15
6. FLOORS: WALLS: AND CEILINGS: Floors, walls, and ceilings clean and in good repair 30# (.2410)	30	
7. STORAGE SPACES: Clean 20#; storage off floor 20# (.2411)	40	
8. LIGHTING AND VENTILATION: Fixtures, grills, vents, blinds, drapes, etc., clean and in good repair 40# (.2412)	40	
9. DRESSING ROOMS AND SHOWERS: Floors, walls, and ceilings clean, in good repair, washable, non-absorbent 30#; fixtures clean, in good repair 40#; facilities for storage of clothes provided, kept clean 20#; soap and towel 10* (.2413)	100	
10. SOLID WASTE DISPOSAL: Impervious, cleanable containers with lids, approved type 20*; clean and in good repair 20#; empties as needed, properly disposed of 40# (.2414)	80	
11. PREMISES: MISCELLANEOUS: Premises neat, clean 30#; no vector breeding or harborage 20#; pesticides and other toxic materials properly handled and stored 30* (.2415)	80	
TOTAL 1000	35	

Additional Comment Sheet Attached

☒ Yes ☐ No

Inspection by:

J.D. REHS

EHS 1746 - Dunn, Jason

INSTRUCTIONS Purpose: General Statute 130A-236 requires the Commission for Health Services to adopt rules governing the sanitation of public, private, and religious schools. This form has been developed to record the results of such inspections. Preparation: Local environmental health specialists shall complete the form every time they conduct an inspection. Prepare an original and two copies for: 1. Original to be left with principal. 2. Copy for the local health department. 3. Copy for the Environmental Health Services Section, Division of Environmental Health. Disposition: Please refer to Records Retention and Disposition Schedule 8.B.6., Inspection Records for County/District Health Departments which is published by the North Carolina Division of Archives & History. Additional forms may be ordered from: Division of Environmental Health, 1632 Mail Service Center, Raleigh, NC 27699-1632, (Courier 52-01-00) EHS 1163 (Revised 7/05) Environmental Health Services Section (Review 7/08)

Comment Addendum to Inspection Report

Establishment Name: THALES ACADEMY APEX JUNIOR HIGH SCHOOL

Establishment ID: 4092440460

Date: 07/20/2026 **Time In:** 9:30 AM **Time Out:** 11:30 AM

Observations and Corrective Actions

4	Repair one urinal that has poor water flow for proper flushing in boys bathroom #238. The urinal plumbing fixture maintenance number is # 238-2.
5	Reattach the loose faucet on one hand wash sink fixture in the gym boys bathroom. Repair two nonfunctional hand wash sink faucets in boys bathrooms #223 and #129. One nonfunctional hand wash sink faucet in both of these boys bathrooms. The hand wash sink fixture maintenance numbers for both faucet repairs are #223-2 and #129-2.

Additional Comments

GC: Middle school facility sanitation inspection completed.